

Introduction

To meet the requirements of water regulations G19.1, G19.3 and G19.4 for sealed or unvented systems a tundish must be used.

The discharge pipework from the expansion valves, temperature relief valves and the temperature and pressure relief valves must fitted in accordance with the local and national water byelaws and also the building regulations Part G3.

Tundishes for water regulations compliance

- Meets the requirements of G19.1, G19.3 & G19.4 and Building regulations Part G3
- Maximum operating temperature 110°C

Product Range

Description	Code
15mm x 22mm straight tundish	TUN23711522*
1/2" male x 3/4" female angled tundish	TUN12M34FA
3/4" male x 1" female angled tundish	TUN34M1FA
1/2" male x 3/4" female straight tundish	TUN34M12FS
22mm x 1" female straight tundish	TUN22X1FS

